

Ellsworth AFB Results reported in parts per trillion (ppt)								
Laboratory Sample ID	570164001	570164002	570164003	570164004	570164005	570164006	570164007	570164008
Sample Date (YYYYMMDD)	20220207	20220207	20220207	20220207	20220207	20220207	20220207	20220207
Analysis Method	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
4:2FTS	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U	≤ 2.3 U	≤ 2.3 UJ	≤ 2.3 UJ	≤ 2.4 U
6:2FTS	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U	3 J	66	14.5 J	96.7
8:2FTS	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U	≤ 2.3 U	15.1	≤ 2.3 U	4
NEtFOSAA	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U	≤ 2.3 U	≤ 2.3 U	≤ 2.3 U	≤ 2.4 U
NMeFOSAA	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U	≤ 2.3 U	≤ 2.3 U	≤ 2.3 U	≤ 2.4 U
PFBS	≤ 1.1 U	18.6	≤ 1.2 U	61.6	≤ 1.2 U	170	20.7	274
PFBA	52.4	8.7 J	5	35.1	122	125 J	186	153
PFDS	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U
PFDA	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U	≤ 1.4 U	0.9 J	≤ 1.4 U	≤ 1.4 U
PFDoA	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U
PFHpS	≤ 1.1 U	9.5	≤ 1.2 U	19.3	≤ 1.2 U	40.3	≤ 1.2 U	23.5
PFHpA	≤ 1.1 U	8.5	≤ 1.2 U	33.9	4.2	112	18.4	113
PFHxS	≤ 1.1 U	174	≤ 1.2 U	547	≤ 1.2 U	941	10.3	1130
PFHxA	≤ 1.4 U	21.8	≤ 1.4 U	101	219	387	75.5	595
PFNS	≤ 1.2 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U
PFNA	≤ 1.1 U	1.8	≤ 1.2 U	4.5	≤ 1.2 U	13.2	≤ 1.2 U	6.6
PFOSA	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	0.7 J	≤ 1.2 U	0.9 J	≤ 1.2 U	≤ 1.2 U
PFOS	≤ 1.4 U	324	≤ 1.4 U	381	≤ 1.4 U	1710	1.3 J	597
PFOA	≤ 1.4 U	34.5	≤ 1.4 U	104	≤ 1.4 U	145	17.5	157
PFPeS	≤ 1.1 U	15	≤ 1.2 U	72	≤ 1.2 U	150	7.1	264
PFPeA	1.8	18.6	≤ 1.2 U	75.3	329	380	153	490
PFTeDA	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U
PFTrDA	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U
PFUnA	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency's (EPA's) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

Ellsworth AFB Results reported in parts per trillion (ppt)								
Laboratory Sample ID	570164009	570164010	570164011	570164012	570164013	570164014	570164015	570164016
Sample Date (YYYYMMDD)	20220207	20220207	20220207	20220207	20220207	20220207	20220207	20220207
Analysis Method	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
4:2FTS	1.2 J	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U	≤ 2.3 U
6:2FTS	97.9	≤ 2.3 UJ	22.7	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U	≤ 2.3 U
8:2FTS	4.7	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U	≤ 2.3 U
NEtFOSAA	≤ 2.4 U	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U	≤ 2.3 U
NMeFOSAA	≤ 2.4 U	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U	≤ 2.3 U
PFBS	257	≤ 1.1 U	97.7	≤ 1.2 U	96.2	≤ 1.2 U	78.7	≤ 1.1 U
PFBA	144	68.5 J	81.6	≤ 1.5 U	27.4	40.4	41.5	3.6
PFDS	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
PFDA	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	0.9 J	≤ 1.4 U
PFDoA	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
PFHpS	24.9	≤ 1.1 U	6.6	≤ 1.2 U	2.1	≤ 1.2 U	28.2	≤ 1.1 U
PFHpA	110	≤ 1.1 U	27.4	≤ 1.2 U	11.4	≤ 1.2 U	42.4	≤ 1.1 U
PFHxS	961	≤ 1.1 U	295	≤ 1.2 U	91.4	≤ 1.2 U	751	≤ 1.1 U
PFHxA	537	≤ 1.4 U	137	≤ 1.5 U	104	≤ 1.5 U	146	≤ 1.4 U
PFNS	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U
PFNA	6.6	≤ 1.1 U	1.9	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	8.6	≤ 1.1 U
PFOSA	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
PFOS	641	≤ 1.4 U	149	≤ 1.5 U	80.4	≤ 1.5 U	756	≤ 1.4 U
PFOA	147	≤ 1.4 U	48	≤ 1.5 U	14.9	≤ 1.5 U	137	≤ 1.4 U
PFPeS	235	≤ 1.1 U	93.1	≤ 1.2 U	41	≤ 1.2 U	107	≤ 1.1 U
PFPeA	477	0.7 J	132	≤ 1.2 U	56	1.5 J	88.3	≤ 1.1 U
PFTeDA	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.5 U	≤ 1.4 U	≤ 1.5 U	≤ 1.4 U	≤ 1.4 U
PFTrDA	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
PFUnA	≤ 1.2 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency's (EPA's) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

Ellsworth AFB Results reported in parts per trillion (ppt)								
Laboratory Sample ID	570164017	570164018	570166001	570166002	570166003	570166005	570166006	570166007
Sample Date (YYYYMMDD)	20220207	20220207	20220207	20220207	20220207	20220209	20220209	20220209
Analysis Method	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
4:2FTS	≤ 2.3 U	≤ 2.3 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U
6:2FTS	≤ 2.3 U	≤ 2.3 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 UJ	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U
8:2FTS	≤ 2.3 U	≤ 2.3 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U
NEtFOSAA	≤ 2.3 U	≤ 2.3 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U
NMeFOSAA	≤ 2.3 U	≤ 2.3 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U	≤ 2.3 U	≤ 2.4 U	≤ 2.4 U
PFBS	16.3	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	86.1	≤ 1.2 U	3.8	3.8
PFBA	10.4	2	≤ 1.5 U	≤ 1.4 U	47.5	3.6	3.8 J	3.8 J
PFDS	≤ 1.1 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U
PFDA	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.5 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U
PFDoA	≤ 1.1 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U
PFHpS	1.2 J	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	4.7	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U
PFHpA	5.4	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	20	≤ 1.2 U	1.4 J	1.4 J
PFHxS	56.5	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	230	≤ 1.2 U	11.2	9.7
PFHxA	21.3	≤ 1.4 U	≤ 1.5 U	≤ 1.4 U	107	≤ 1.4 U	3.6	4
PFNS	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.2 U	≤ 1.3 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U
PFNA	≤ 1.1 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U
PFOSA	≤ 1.1 U	0.8 J	1.4 J	1.5 J	1.6 J	1.2 J	0.7 J	0.7 J
PFOS	16.6	≤ 1.4 U	0.9 J	≤ 1.4 U	61.4	≤ 1.4 U	13.5	12.5
PFOA	5.8	≤ 1.4 U	≤ 1.5 U	≤ 1.4 U	21.2	≤ 1.4 U	3.7	3.9
PFPeS	13.5	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	69	≤ 1.2 U	1.4 J	1.3 J
PFPeA	15.9	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	82.9	2.1	3.1	3.2
PFTeDA	≤ 1.4 U	≤ 1.4 U	≤ 1.5 U	≤ 1.4 U	≤ 1.5 U	≤ 1.4 U	≤ 1.5 U	≤ 1.5 U
PFTrDA	≤ 1.1 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U
PFUnA	≤ 1.1 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency's (EPA's) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

Ellsworth AFB Results reported in parts per trillion (ppt)								
Laboratory Sample ID	570166009	570166008	570166011	570166012	570166013	570166014	570166015	570166016
Sample Date (YYYYMMDD)	20220209	20220209	20220210	20220210	20220210	20220210	20220210	20220210
Analysis Method	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
4:2FTS	≤ 2.4 U	≤ 2.4 U	≤ 2.5 UJ	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U
6:2FTS	≤ 2.4 U	≤ 2.4 UJ	≤ 2.5 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U
8:2FTS	≤ 2.4 U	≤ 2.4 U	≤ 2.5 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U
NEtFOSAA	≤ 2.4 U	≤ 2.4 U	≤ 2.5 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U
NMeFOSAA	≤ 2.4 U	≤ 2.4 U	≤ 2.5 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U	≤ 2.4 U	≤ 2.5 U
PFBS	3.9	≤ 1.2 U	≤ 1.2 U	3.6	≤ 1.2 U	109	≤ 1.2 U	70.6
PFBA	4.3 J	1.8 J	5.1	4.5 J	≤ 1.5 U	57.6	25	29
PFDS	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U
PFDA	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.5 U	≤ 1.4 U	1 J	≤ 1.4 U	≤ 1.5 U
PFDoA	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U
PFHpS	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	45.6	≤ 1.2 U	13.9
PFHpA	1.6 J	≤ 1.2 U	≤ 1.2 U	1.3 J	≤ 1.2 U	52.5	≤ 1.2 U	12.7
PFHxS	13.4	≤ 1.2 U	≤ 1.2 U	11.9	≤ 1.2 U	1320	≤ 1.2 U	328
PFHxA	4.5	≤ 1.4 U	≤ 1.5 U	4.4	≤ 1.5 U	129	≤ 1.4 U	82.9
PFNS	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U	≤ 1.3 U
PFNA	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	10.4	≤ 1.2 U	2
PFOSA	1.4 J	0.8 J	≤ 1.2 U	1.6 J	1.3 J	1.4 J	0.7 J	1 J
PFOS	15.1	≤ 1.4 U	≤ 1.5 U	13.2	≤ 1.5 U	1370	≤ 1.4 U	411
PFOA	5.4	≤ 1.4 U	≤ 1.5 U	4.6	≤ 1.5 U	164	≤ 1.4 U	53.4
PFPeS	1.7	≤ 1.2 U	≤ 1.2 U	1.5 J	≤ 1.2 U	155	≤ 1.2 U	49
PFPeA	3.7	≤ 1.2 U	4.2	3.4	≤ 1.2 U	100	1.8	56.6
PFTeDA	≤ 1.4 U	≤ 1.4 U	≤ 1.5 U	≤ 1.5 U	≤ 1.5 U	≤ 1.5 U	≤ 1.4 U	≤ 1.5 U
PFTrDA	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U
PFUnA	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency's (EPA's) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

Ellsworth AFB Results reported in parts per trillion (ppt)							
Laboratory Sample ID	570166018	570166019	570166020	570166021	570166022	570166023	570166024
Sample Date (YYYYMMDD)	20220210	20220210	20220210	20220210	20220210	20220210	20220210
Analysis Method	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt
4:2FTS	≤ 2.5 U	≤ 2.6 U	≤ 2.2 UJ	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 UJ
6:2FTS	≤ 2.5 UJ	≤ 2.6 UJ	≤ 2.2 U	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U
8:2FTS	≤ 2.5 U	≤ 2.6 U	≤ 2.2 U	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U
NEtFOSAA	≤ 2.5 U	≤ 2.6 U	≤ 2.2 U	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U
NMeFOSAA	≤ 2.5 U	≤ 2.6 U	≤ 2.2 U	≤ 2.4 U	≤ 2.4 U	≤ 2.4 U	≤ 2.3 U
PFBS	9.6	9.9	≤ 1.1 U	267	273	≤ 1.2 U	37.6
PFBA	4.9 J	4.9 J	≤ 1.4 U	116	116	≤ 1.4 U	28.2
PFDS	≤ 1.2 U	≤ 1.3 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U
PFDA	≤ 1.4 U	≤ 1.5 U	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U
PFDoA	≤ 1.2 U	≤ 1.3 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U
PFHpS	1.2 J	1.4 J	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	4.7
PFHpA	2.7	2.8	≤ 1.1 U	47.2	51.8	≤ 1.2 U	8.4
PFHxS	46.9	44.5	≤ 1.1 U	735	760	≤ 1.2 U	169
PFHxA	9.4	9.9	≤ 1.4 U	288	278	≤ 1.4 U	36.3
PFNS	≤ 1.3 U	≤ 1.4 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U
PFNA	≤ 1.2 U	≤ 1.3 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	1.2 J
PFOSA	≤ 1.2 U	0.8 J	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U
PFOS	57	60.2	0.7 J	≤ 1.5 U	≤ 1.4 U	1.1 J	209
PFOA	9.6	10.6	≤ 1.4 U	80.8	80.1	≤ 1.4 U	17.8
PFPeS	5	5.1	≤ 1.1 U	201	214	≤ 1.2 U	35.1
PFPeA	9.1	9.4	≤ 1.1 U	167	153	≤ 1.2 U	23.5
PFTeDA	≤ 1.5 U	≤ 1.6 U	≤ 1.4 U	≤ 1.5 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U
PFTrDA	≤ 1.2 U	≤ 1.3 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U
PFUnA	≤ 1.2 U	≤ 1.3 U	≤ 1.1 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency's (EPA's) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.