

Homestead Air Reserve Base Results reported in parts per trillion (ppt)								
Laboratory Sample ID	FA91932-4	FA91932-1	FA91932-2	FA92737-1	FA92737-2	FA93316-2	FA93316-1	FA93316-4
Sample Date (YYYYMMDD)	20211221	20211221	20211221	20220127	20220127	20220221	20220221	20220221
Analysis Method	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
4:2FTS	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8.3 U	≤ 8.3 U	≤ 8 U	≤ 8 U	≤ 8 U
6:2FTS	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8.3 U	≤ 8.3 U	≤ 8 U	8 J	≤ 8 U
8:2FTS	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8.3 U	≤ 8.3 U	≤ 8 U	≤ 8 U	≤ 8 U
NEtFOSAA	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8.3 U	≤ 8.3 U	≤ 8 U	≤ 8 U	≤ 8 U
NMeFOSAA	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8.3 U	≤ 8.3 U	≤ 8 U	≤ 8 U	≤ 8 U
PFBS	8.9	7.9 J	7.9 J	7.6 J	7.4 J	≤ 4 U	8.6	≤ 4 U
PFBA	10.7 J	11.9 J	11.6 J	10.5 J	10.2 J	≤ 8 U	23.7	≤ 8 U
PFDS	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4.2 U	≤ 4.2 U	≤ 4 U	≤ 4 U	≤ 4 U
PFDA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4.2 U	≤ 4.2 U	≤ 4 U	≤ 4 U	≤ 4 U
PFDoA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4.2 U	≤ 4.2 U	≤ 4 U	≤ 4 U	≤ 4 U
PFHpS	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4.2 U	≤ 4.2 U	≤ 4 U	2.6 J	≤ 4 U
PFHpA	6.7 J	8.9	7.7 J	7.1 J	7.4 J	≤ 4 U	11.1	≤ 4 U
PFHxS	27.4	33.1	25.8	26.4	26.2	≤ 4 U	53.3	≤ 4 U
PFHxA	13.4	13.9	13.1	13.1	12.2	≤ 4 U	35.5	≤ 4 U
PFNS	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4.2 U	≤ 4.2 U	≤ 4 U	≤ 4 U	≤ 4 U
PFNA	≤ 4 U	2.5 J	≤ 4 U	≤ 4.2 U	≤ 4.2 U	≤ 4 U	≤ 4 U	≤ 4 U
PFOSA	≤ 4 U	3.3 J	≤ 4 U	≤ 4.2 U	≤ 4.2 U	≤ 4 U	≤ 4 U	≤ 4 U
PFOS	43.9	68.5 J	36.3 J	37.8	37.5	≤ 4 U	73.4	≤ 4 U
PFOA	8.3	16	11	10.3	10.4	≤ 4 U	18.9	≤ 4 U
PFPeS	2.4 J	≤ 4 U	≤ 4 U	≤ 4.2 U	≤ 4.2 U	≤ 4 U	4.5 J	≤ 4 U
PFPeA	12.8	13.6	13.2	12.7	12.9	≤ 4 U	24.6	≤ 4 U
PFTeDA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4.2 U	≤ 4.2 U	≤ 4 U	≤ 4 U	≤ 4 U
PFTrDA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4.2 U	≤ 4.2 U	≤ 4 U	≤ 4 U	≤ 4 U
PFUnA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4.2 U	≤ 4.2 U	≤ 4 U	≤ 4 U	≤ 4 U

**Notes**

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency's (EPA's) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

Homestead Air Reserve Base Results reported in parts per trillion (ppt)								
Laboratory Sample ID	FA93316-3	FA93316-6	FA93316-5	FA93316-7	FA93316-8	FA93316-9	FA93848-1	FA93848-2
Sample Date (YYYYMMDD)	20220221	20220221	20220221	20220221	20220221	20220221	20220310	20220310
Analysis Method	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
4:2FTS	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U
6:2FTS	≤ 8 U	≤ 8 U	17.3	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U
8:2FTS	≤ 8 U	≤ 8 U	8.3 J	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U
NEtFOSAA	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U
NMeFOSAA	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U
PFBS	9.1	≤ 4 U	13.7	8.5	8.6	10.1	≤ 4 U	≤ 4 U
PFBA	17.2	≤ 8 U	25.1	14.1 J	13.6 J	9.1 J	≤ 8 U	≤ 8 U
PFDS	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFDA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFDoA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFHpS	≤ 4 U	≤ 4 U	4.5 J	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFHpA	9.4	≤ 4 U	21.5	10	9.6	6 J	≤ 4 U	≤ 4 U
PFHxS	39.2	≤ 4 U	130	32.2	31	23.9	≤ 4 U	≤ 4 U
PFHxA	22.9	≤ 4 U	49.4	15.8	16.1	8.1	≤ 4 U	≤ 4 U
PFNS	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFNA	≤ 4 U	≤ 4 U	22.4	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFOSA	≤ 4 U	≤ 4 U	5.3 J	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFOS	58.3	≤ 4 U	142	46.4	45.3	46.2	≤ 4 U	≤ 4 U
PFOA	15	≤ 4 U	39.8	13.1	13.3	8.2	≤ 4 U	≤ 4 U
PFPeS	3 J	≤ 4 U	7.1 J	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFPeA	25.5	≤ 4 U	36.9	16.8	16.4	9.8	≤ 4 U	≤ 4 U
PFTeDA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFTrDA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFUnA	≤ 4 U	≤ 4 U	9.9	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U

**Notes**

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency's (EPA's) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

Homestead Air Reserve Base Results reported in parts per trillion (ppt)		
Laboratory Sample ID	FA93848-3	FA93848-4
Sample Date (YYYYMMDD)	20220310	20220310
Analysis Method	QSM B-15	QSM B-15
Units	ppt	ppt
4:2FTS	≤ 8 U	≤ 8 U
6:2FTS	≤ 8 U	≤ 8 U
8:2FTS	≤ 8 U	≤ 8 U
NEtFOSAA	≤ 8 U	≤ 8 U
NMeFOSAA	≤ 8 U	≤ 8 U
PFBS	≤ 4 U	≤ 4 U
PFBA	≤ 8 U	≤ 8 U
PFDS	≤ 4 U	≤ 4 U
PFDA	≤ 4 U	≤ 4 U
PFDoA	≤ 4 U	≤ 4 U
PFHpS	≤ 4 U	≤ 4 U
PFHpA	≤ 4 U	≤ 4 U
PFHxS	≤ 4 U	≤ 4 U
PFHxA	≤ 4 U	≤ 4 U
PFNS	≤ 4 U	≤ 4 U
PFNA	≤ 4 U	≤ 4 U
PFOSA	≤ 4 U	≤ 4 U
PFOS	≤ 4 U	≤ 4 U
PFOA	≤ 4 U	≤ 4 U
PFPeS	≤ 4 U	≤ 4 U
PFPeA	≤ 4 U	≤ 4 U
PFTeDA	≤ 4 U	≤ 4 U
PFTTrDA	≤ 4 U	≤ 4 U
PFUnA	≤ 4 U	≤ 4 U

**Notes**

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency's (EPA's) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.