

Hurlburt Field Results reported in parts per trillion (ppt)								
Laboratory Sample ID	FA90556-2	FA90556-3	FA90556-4	FA91917-2	FA91917-3	FA91916-1	FA91917-4	FA91916-3
Sample Date (YYYYMMDD)	20211104	20211104	20211104	20211220	20211220	20211220	20211220	20211220
Analysis Method	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15	QSM B-15
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
4:2FTS	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U
6:2FTS	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U
8:2FTS	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U
NEtFOSAA	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U
NMeFOSAA	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U	≤ 8 U
PFBS	9.2	10.3	362	160	155	6 J	8.7	18
PFBA	≤ 8 U	≤ 8 U	13.4 J	9.8 J	9.5 J	6.2 J	≤ 8 U	4.4 J
PFDS	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFDA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	4 J
PFDoA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFHpS	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFHpA	5.7 J	5.7 J	11.5	11	9.3	6.4 J	3.5 J	5.8 J
PFHxS	4.2 J	4.4 J	13.4	12.5	11.7	18.5	8.6	5.2 J
PFHxA	4.4 J	4.6 J	22.8	16.1	15.4	8.7	4.9 J	7.5 J
PFNS	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFNA	≤ 4 U	≤ 4 U	7.3 J	5 J	5.2 J	≤ 4 U	≤ 4 U	≤ 4 U
PFOSA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFOS	15.6	16.6	105	98.7	102	29.5	28	32.6
PFOA	9.8	10.1	30.8	26.8	27.1	20	9.8	15.2
PFPeS	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFPeA	4.2 J	4.3 J	29.8	20.9	20	9.2	5.6 J	6.9 J
PFTeDA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFTrDA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U
PFUnA	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U	≤ 4 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency's (EPA's) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

Hurlburt Field Results reported in parts per trillion (ppt)	
Laboratory Sample ID	FA91916-4
Sample Date (YYYYMMDD)	20211220
Analysis Method	QSM B-15
Units	ppt
4:2FTS	≤ 8 U
6:2FTS	≤ 8 U
8:2FTS	≤ 8 U
NEtFOSAA	≤ 8 U
NMeFOSAA	≤ 8 U
PFBS	17.3
PFBA	≤ 8 U
PFDS	≤ 4 U
PFDA	3.9 J
PFDoA	≤ 4 U
PFHpS	≤ 4 U
PFHpA	5.6 J
PFHxS	4.9 J
PFHxA	7.5 J
PFNS	≤ 4 U
PFNA	≤ 4 U
PFOSA	2.3 J
PFOS	32.2
PFOA	14.8
PFPeS	≤ 4 U
PFPeA	6.6 J
PFTeDA	≤ 4 U
PFTTrDA	≤ 4 U
PFUnA	≤ 4 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency's (EPA's) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.