

NCTAMSLANT DET CUTLER Results reported in parts per trillion (ppt)								
Laboratory Sample ID	F3754-FS	F3767-FS	F3756-FS	F3758-FS	F3760-FS	F3761-FS	F3766-FS	F3763-FS
Sample Date (YYYYMMDD)	20211005	20211006	20211006	20211006	20211006	20211006	20211006	20211006
Analysis Method	537	537	537	537	537	537	537	537
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
HFPO-DA	≤ 1.3 U	≤ 1.1 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
PFOS	36.1	18.8	5.3	23.3	25.7	29.2	33.2	44.2
PFUnA	≤ 1.3 U	≤ 1.1 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
NMeFOSAA	≤ 1.3 U	≤ 1.1 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
NEtFOSAA	≤ 1.5 U	≤ 1.4 U	≤ 1.6 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U
PFHxA	16	8.2	18.1	12.7	12.3	9.9	15.2	40.3
PFDoA	≤ 1.3 U	≤ 1.1 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
PFOA	16.2	9.7	38.3	8.4	7.7	7.8	8.2	26
PFDA	≤ 1.3 U	≤ 1.1 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
PFHxS	40.1	15.5	5.8	32.9	35.6	33.3	28.7	60.2
PFBS	2.5	7.2	6	7.9	8.8	8.2	10.1	13.7
PFHpA	7.8	2.2 J	16.1	4.7	4.3	4.4	4.8	7.5
PFNA	1.3 J	0.5 J	2.8	0.4 J	0.4 J	0.5 J	0.5 J	0.4 J
PFTeDA	≤ 1.3 U	≤ 1.1 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
PFTrDA	≤ 1.3 U	≤ 1.1 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
9CI-PF3ONS	≤ 1.3 U	≤ 1.1 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
11CI-PF3OUdS	≤ 1.3 U	≤ 1.1 U	≤ 1.3 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.1 U
ADONA	≤ 1 U	≤ 0.9 U	≤ 1 U	≤ 0.9 U	≤ 0.9 U	≤ 0.9 U	≤ 0.9 U	≤ 0.9 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency’s (EPA’s) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

NCTAMSLANT DET CUTLER Results reported in parts per trillion (ppt)								
Laboratory Sample ID	F3776-FS	F3769-FS	F3771-FS	F3773-FS	F3774-FS	F6949-FS	F6938-FS	F6940-FS
Sample Date (YYYYMMDD)	20211006	20211006	20211006	20211006	20211006	20211215	20211216	20211216
Analysis Method	537	537	537	537	537	537	537	537
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
HFPO-DA	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFOS	39.9	35	73.8	71.8	62.9	28.5	7.3	30.4
PFUnA	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
NMeFOSAA	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
NEtFOSAA	≤ 1.4 U	≤ 1.5 U	≤ 1.4 U	≤ 1.4 U	≤ 1.5 U	≤ 1.5 U	≤ 1.5 U	≤ 1.6 U
PFHxA	22.7	8.1	28.2	28.5	21.9	16	20.3	11.3
PFDoA	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFOA	9.3	9.4	10.7	11	9.2	17.2	41.9	10
PFDA	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFHxS	43.5	30.8	56.1	56.9	47.4	36.3	8.9	32
PFBS	12.1	6.4	14.8	14	12.3	1.7 J	6.4	7.6
PFHpA	6.6	4	7.7	7.8	6.5	7.4	19.7	5.6
PFNA	0.5 J	1.3 J	0.8 J	0.7 J	0.8 J	1.4 J	3.7	0.6 J
PFTeDA	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFTTrDA	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
9CI-PF3ONS	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
11CI-PF3OUdS	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
ADONA	≤ 1 U	≤ 1 U	≤ 0.9 U	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1.1 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency’s (EPA’s) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

NCTAMSLANT DET CUTLER Results reported in parts per trillion (ppt)								
Laboratory Sample ID	F6950-FS	F6942-FS	F6944-FS	F6946-FS	F7226-FS	F7210-FS	F7211-FS	F7209-FS
Sample Date (YYYYMMDD)	20211216	20211216	20211216	20211216	20220103	20220104	20220104	20220104
Analysis Method	537	537	537	537	537	537	537	537
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
HFPO-DA	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFOS	30.2	30.7	36.5	27.1	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	394
PFUnA	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
NMeFOSAA	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
NEtFOSAA	≤ 1.6 U	≤ 1.6 U	≤ 1.5 U	≤ 1.6 U	≤ 1.6 U	≤ 1.5 U	≤ 1.5 U	≤ 1.5 U
PFHxA	11.1	15.8	20.2	6.8	≤ 1.8 U	≤ 1.8 U	≤ 1.8 U	74.4
PFDoA	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFOA	9.7	8.8	8.3	8.9	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	36.7
PFDA	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFHxS	33.7	28.9	36.3	24.5	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	216
PFBS	7.8	9	10.7	4.7	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	42.8
PFHpA	5.5	5.8	6.9	3.9	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	23.2
PFNA	0.6 J	0.5 J	0.5 J	1.2 J	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	3.1
PFTeDA	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFTrDA	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
9CI-PF3ONS	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
11CI-PF3OUdS	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
ADONA	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency’s (EPA’s) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

NCTAMSLANT DET CUTLER Results reported in parts per trillion (ppt)								
Laboratory Sample ID	F7213-FS	F7214-FS	F7212-FS	F7215-FS	F7216-FS	F7230-FS	F7217-FS	F7218-FS
Sample Date (YYYYMMDD)	20220104	20220104	20220104	20220104	20220104	20220104	20220104	20220104
Analysis Method	537	537	537	537	537	537	537	537
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
HFPO-DA	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFOS	≤ 1.3 U	≤ 1.4 U	372	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFUnA	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
NMeFOSAA	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
NEtFOSAA	≤ 1.6 U	≤ 1.6 U	≤ 1.6 U	≤ 1.6 U	≤ 1.6 U	≤ 1.5 U	≤ 1.6 U	≤ 1.6 U
PFHxA	≤ 1.8 U	≤ 1.9 U	81.8	≤ 1.9 U	≤ 1.8 U	≤ 1.8 U	≤ 1.8 U	≤ 1.8 U
PFDoA	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFOA	≤ 1.3 U	≤ 1.4 U	40.3	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFDA	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFHxS	≤ 1.3 U	≤ 1.4 U	208	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFBS	≤ 1.3 U	≤ 1.4 U	45.1	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFHpA	≤ 1.3 U	≤ 1.4 U	25.4	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFNA	≤ 1.3 U	≤ 1.4 U	3.4	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFTeDA	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFTrDA	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
9CI-PF3ONS	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
11CI-PF3OUdS	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
ADONA	≤ 1 U	≤ 1.1 U	≤ 1.1 U	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency’s (EPA’s) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

NCTAMSLANT DET CUTLER Results reported in parts per trillion (ppt)								
Laboratory Sample ID	F7231-FS	F7219-FS	F7220-FS	F7221-FS	F7223-FS	F7224-FS	F7222-FS	F7225-FS
Sample Date (YYYYMMDD)	20220104	20220104	20220104	20220104	20220104	20220104	20220104	20220104
Analysis Method	537	537	537	537	537	537	537	537
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
HFPO-DA	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFOS	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	339	≤ 1.3 U
PFUnA	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
NMeFOSAA	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
NEtFOSAA	≤ 1.6 U	≤ 1.5 U	≤ 1.6 U	≤ 1.6 U	≤ 1.6 U	≤ 1.6 U	≤ 1.6 U	≤ 1.6 U
PFHxA	≤ 1.8 U	≤ 1.8 U	≤ 1.9 U	≤ 1.8 U	≤ 1.9 U	≤ 1.9 U	40	≤ 1.9 U
PFDoA	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFOA	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	24.5	≤ 1.3 U
PFDA	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFHxS	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	234	≤ 1.3 U
PFBS	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	29.9	≤ 1.3 U
PFHpA	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	15.2	≤ 1.3 U
PFNA	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	2.4 J	≤ 1.3 U
PFTeDA	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
PFTrDA	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
9CI-PF3ONS	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
11CI-PF3OUdS	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U
ADONA	≤ 1 U	≤ 1 U	≤ 1.1 U	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1.1 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency’s (EPA’s) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

NCTAMSLANT DET CUTLER Results reported in parts per trillion (ppt)								
Laboratory Sample ID	F7232-FS	F7228-FS	F7229-FS	F7227-FS	F7207-FS	F8071-FS	F8078-FS	F8070-FS
Sample Date (YYYYMMDD)	20220104	20220104	20220104	20220104	20220104	20220127	20220127	20220127
Analysis Method	537	537	537	537	537	537	537	537
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
HFPO-DA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U
PFOS	≤ 1.3 U	2.9	1.2 J	517	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	65.5
PFUnA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U
NMeFOSAA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U
NEtFOSAA	≤ 1.6 U	≤ 1.6 U	≤ 1.5 U	≤ 1.5 U	≤ 1.6 U	≤ 1.6 U	≤ 1.5 U	≤ 1.5 U
PFHxA	≤ 1.8 U	4	≤ 1.8 U	483	3.5	≤ 1.8 U	≤ 1.8 U	47
PFDoA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U
PFOA	≤ 1.3 U	7	0.8 J	884	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	35.6
PFDA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	0.5 J	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U
PFHxS	≤ 1.3 U	9.5	1.2 J	1760	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	65.5
PFBS	≤ 1.3 U	0.7 J	≤ 1.3 U	125	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	10.9
PFHpA	≤ 1.3 U	1 J	≤ 1.3 U	110	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	9.6
PFNA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	19.2	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	0.5 J
PFTeDA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U
PFTrDA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U
9CI-PF3ONS	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U
11CI-PF3OUdS	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.2 U
ADONA	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1 U	≤ 1.1 U	≤ 1 U	≤ 1 U	≤ 1 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency’s (EPA’s) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

NCTAMSLANT DET CUTLER Results reported in parts per trillion (ppt)								
Laboratory Sample ID	F8073-FS	F8072-FS	F8075-FS	F8074-FS	F8077-FS	F8076-FS	F8373-FS	F8374-FS
Sample Date (YYYYMMDD)	20220127	20220127	20220127	20220127	20220127	20220127	20220210	20220210
Analysis Method	537	537	537	537	537	537	537	537
Units	ppt	ppt	ppt	ppt	ppt	ppt	ppt	ppt
HFPO-DA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U
PFOS	≤ 1.3 U	17.8	23.8	59.8	≤ 1.3 U	50.2	≤ 1.4 U	≤ 1.3 U
PFUnA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U
NMeFOSAA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U
NEtFOSAA	≤ 1.6 U	≤ 1.6 U	≤ 1.6 U	≤ 1.6 U	≤ 1.6 U	≤ 1.6 U	≤ 1.7 U	≤ 1.6 U
PFHxA	≤ 1.9 U	16.6	26.5	25.7	≤ 1.9 U	18.5	≤ 2 U	≤ 1.9 U
PFDoA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U
PFOA	≤ 1.3 U	27.9	7	9.7	≤ 1.3 U	8	≤ 1.4 U	≤ 1.3 U
PFDA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U
PFHxS	≤ 1.3 U	23.7	34.2	43.5	≤ 1.3 U	37.2	≤ 1.4 U	≤ 1.3 U
PFBS	≤ 1.3 U	7.6	11.4	10.8	≤ 1.3 U	9	≤ 1.4 U	≤ 1.3 U
PFHpA	≤ 1.3 U	12.7	8	7.7	≤ 1.3 U	6.4	≤ 1.4 U	≤ 1.3 U
PFNA	≤ 1.3 U	2.4 J	≤ 1.3 U	0.7 J	≤ 1.3 U	0.5 J	≤ 1.4 U	≤ 1.3 U
PFTeDA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U
PFTrDA	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U
9CI-PF3ONS	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U
11CI-PF3OUdS	≤ 1.3 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U	≤ 1.3 U	≤ 1.4 U	≤ 1.3 U
ADONA	≤ 1.1 U	≤ 1 U	≤ 1 U	≤ 1.1 U	≤ 1.1 U	≤ 1 U	≤ 1.1 U	≤ 1 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency’s (EPA’s) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.

NCTAMSLANT DET CUTLER Results reported in parts per trillion (ppt)					
Laboratory Sample ID	F8376-FS	F8375-FS	F8378-FS	F8371-FS	F8370-FS
Sample Date (YYYYMMDD)	20220210	20220210	20220210	20220210	20220210
Analysis Method	537	537	537	537	537
Units	ppt	ppt	ppt	ppt	ppt
HFPO-DA	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U
PFOS	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	1.1 J	0.5 J
PFUnA	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U
NMeFOSAA	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U
NEtFOSAA	≤ 1.6 U	≤ 1.6 U	≤ 1.7 U	≤ 1.6 U	≤ 1.6 U
PFHxA	≤ 1.9 U	≤ 1.9 U	≤ 2 U	1.9 J	≤ 1.8 U
PFDoA	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U
PFOA	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	2.1 J	≤ 1.3 U
PFDA	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U
PFHxS	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	3.4	≤ 1.3 U
PFBS	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U
PFHpA	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U
PFNA	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U
PFTeDA	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U
PFTrDA	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U
9CI-PF3ONS	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U
11CI-PF3OUdS	≤ 1.3 U	≤ 1.4 U	≤ 1.4 U	≤ 1.4 U	≤ 1.3 U
ADONA	≤ 1.1 U	≤ 1.1 U	≤ 1.1 U	≤ 1.1 U	≤ 1 U

Notes

Where there was individual or combined levels of PFOS and/or PFOA in drinking water above the 2016 U.S. Environmental Protection Agency’s (EPA’s) lifetime drinking water health advisories (HAs) resulting from DoD activities, the Department immediately took actions to address the drinking water exposure of 70 ppt.

J - The reported result was an estimate value.

U - The analyte was not detected and was reported as less than the Limit of Detection (LOD). The LOD has been adjusted for any dilution or concentration of the sample.

UJ - The analyte was not detected and was reported as less than the Limit of Detection (LOD). However, the associated numerical value is approximate.